



GOODMAN COMPANY RE-ANNOUNCES RECALL OF AIR CONDITIONER/HEAT PUMP UNITS DUE TO FIRE

Release # 10-058

Firm's Recall Hotline: (800) 366-0339
CPSC Recall Hotline: (800) 638-2772
CPSC Media Contact: (301) 504-7908

WASHINGTON, D.C. - The U.S. Consumer Product Safety Commission, in cooperation with the firm named below, today announced a voluntary recall of the following consumer product.

Name of Product: Packaged Terminal Air Conditioner/Heat Pump (PTACs) Units

Units: About 30,000; previously recalled in August 2008

Manufacturer: Goodman Company, LP, of Houston, Texas

Hazard: The power cords on the PTACs can overheat, posing a burn or fire hazard.

Incidents/Injuries: Goodman has received eleven reports of smoke or fire associated with the PTAC's power cords. No injuries have been reported.

Description: The recall includes 5.0 kW Amana-brand, Comfort-Aire-brand and Century-brand Packaged Terminal Air Conditioner units with model numbers PTxxx3x50xx (Amana) and EKTxxx-150x (Comfort-Aire and Century) and serial numbers 0702112056 through 0804237539. The model and serial numbers are located on the control board plate found under the PTAC unit's front cover.

Sold at: Goodman and heating and cooling equipment dealers nationwide from February 2007 through June 2008 for between \$700 and \$1,000.

Manufactured in: United States

Remedy: Consumers should contact Goodman to receive a free replacement power cord. Commercial and institutional owners will be contacted directly and will install the power cord.

Consumer Contact: For additional information regarding Amana-brand units, contact Goodman at (800) 366-0339 between 8 a.m. and 5 p.m. CT Monday through Friday; for Comfort-Aire and Century-brand units call (877) 442-4482 between 8 a.m. and 5 p.m. ET Monday through Friday; or visit www.regcen.com/ptaccord for all products.

To see this recall on CPSC's web site, including a picture of the recalled product, please go to:
<http://www.cpsc.gov/cpsc/pub/prerel/prhtml10/10058.html>



NYS Department of State

OFFICE OF
**FIRE PREVENTION
& CONTROL**

phone 518.474.6746
fax 518.474.3240
email fire@dos.state.ny.us